

Cable Gland Type A8 - (Single Compression Gland designed for Unarmoured Flat Cable)

Ex d : Ex e : Ex nR : Ex ta : IP66 : IP68
Class I Div 2 : AEx e : AEx ta


Part Numbers:

A	B	B	F
		S	



“A8” type glands are certified Flameproof Ex d, Increased Safety Ex e, Restricted Breathing Ex nR and Dust Protected Ex ta. They are suitable for use in Zone 1 and 2 for Gas Groups IIA, IIB and IIC and additionally for use in Zones 20, 21 and 22 for Dust Groups IIIA, IIIB and IIIC. Developed for flat cables, they provide controlled Ex d sealing and have been tested to IP66 and IP68 to 50 metres. The A8 version is designed to accommodate unarmoured and armoured cables where sealing and retention is required only on the outer sheath.

Compliance Standards:	EN 60079-0, EN 60079-1, EN 60079-7, EN 60079-15, EN 60079-31 IEC 60079-0, IEC 60079-1, IEC 60079-7, IEC 60079-31 & IEC 60529 UL514B, UL1203, ANSI/UL 60079-0/7, ISA 60079-31
Certification:	ATEX II 1D 2G Ex d IIC Gb / Ex e IIC Gb / Ex ta IIIC Da II 3G Ex nR IIC Gc IECEX Ex d IIC Gb / Ex e IIC Gb / Ex ta IIIC Da NEC - USA Class I Zone 1 AEx e IIC Gb / Class II Zone 20 AEx ta IIIC Da Class II Division 1, Groups E, F & G Class III, Enclosure Type 4X EAC Exd IICU / Exe IIU / ExnR IIU SAC - China Ex d IIC / Ex e IIC INMETRO - Brazil Ex d IIC Gb / Ex e IIC Gb / Ex ta IIIC Da / Ex nR IIC Gc UKRAINE Ex d IIC X / Ex e II X CCoE Petroleum Rules 2002 (PESO) ABS Specified ABS Rules LLOYD'S Enclosure Systems (Part 1B) RMRS Part XI of RS Rules for the classification & construction of sea-going ships (ed. 2014)



Certificate No.	ATEX SIRA 01ATEX1270X & SIRA 09ATEX1221X IECEX IECEX SIR 05.0020X NEC - USA CSA 2627370 EAC RU C-GB.ГБ06.В.00098 SAC - China NEPSI GYJ16.1398X INMETRO - Brazil NCC 13.2187 X UKRAINE UA.TR.047.C.0408-13 & 2937 CCoE - India PESO P365300/2 & P365300/6 ABS 14-LD463991-1-PDA LLOYD'S 10/00056(E1) RMRS 14.02755.315
------------------------	---

IP Rating: IP66 & IP68 (50 metres - 7 Days)
Operating Temperature: Silicone Seals -60°C to +180°C
Materials: Brass or Stainless Steel
Plating: Electroless Nickel

Example Part Numbering A8BF/NP/20R/M20
(See below for details)

A	Gland for Unarmoured Cables	
B	Silicone Seal for flat cables	
B	Brass (B) / Stainless Steel (S)	
F	Multiple Certification	
NP	Nickel Plated	
20R	Gland shell size	
M20	M20 x 1.5mm Male Entry Thread	
Optional Accessories	Locknut	Brass (ACBLN) / Stainless Steel (ACSLN)
	Earth tag	Brass (ACBET) / Stainless Steel (ACSET)
	IP Washers	Nylon (ACNSW) / Fibre (ACFSW) / PTFE (ACPSW)
	Serrated Washers	Stainless Steel (ACSSW)

CABLE GLAND SELECTION TABLE												
Gland Size	Entry Thread Size		ISO Thread Length [B]	Cable Outer Sheath [D]				Nominal Protrusion Length [L]	Dimensions/Weight (Metric Versions)			Metric Thread Shroud Size
	Metric	NPT		Width		Thickness			Across Flats [A]	Across Corners	Weight Kgs (Metric)	
				Min	Max	Min	Max					
20S	M20 x 1.5 M25 x 1.5	3/4" or 1/2"	16	6.3	11.7	4.0	7.0	33	30.0	33.0	0.104	N/A
20R	M20 x 1.5 M25 x 1.5	3/4" or 1/2"	16	8.1	13.5	5.8	6.2	33	30.0	33.0	0.104	N/A
20	M20 x 1.5 M25 x 1.5	3/4" or 1/2"	16	10.3	13.5	5.6	9.0	33	30.0	33.0	0.103	N/A
** 25	M25 x 1.5	3/4" or 1"	16	10.6	16.2	4.0	7.0	31	37.6	41.4	0.162	N/A

All dimensions in mm

- Notes:
- Gland size does not necessarily equate to the entry thread size.
 - Dimensions (A) & (B) may differ for glands with non metric entry threads. Please refer to our "Thread Reference Tables" for specific dimensions.
 - Assembly instructions must be read prior to installation and adhered to in full.
 - Peppers supplies cable glands with parallel entry threads that conform to the flameproof threaded joint requirements of IEC/EN 60079-1 and other equivalent standards. They usually incorporate a thread run out according to the available machining techniques and will not have a full form thread for the entire length. Peppers Cable Glands Limited will not be held responsible for clients' installations where this has not been taken into account.
 - When selecting IP Washer material for gland kits, please be aware of the accessories temperature range to ensure they are suitable for the intended installation.
 - Where approval in addition to ATEX, IECEx and CSA is required, this must be clearly requested at time of enquiry / order.
 - ** Size 25mm is only ATEX & IECEx certified.